

**3.5 Electric and Gas Utilities**

**Comment 3.5-1 (Letter to Planning Board, December 16, 2011, Robert Geneslaw):** Page 3.5-1. Refers to installation of above ground fuel oil storage tanks and later indicates there will be no above ground fuel oil storage tanks. This should be clarified.

***Response 3.5-1:*** *The project is planned for propane and/or electric energy, not fuel oil. If propane fuel is used the tanks will be sited above ground in accordance with NYS building code standards and local zoning requirements.*