

APPENDIX C  
Correspondence



Robert P. Astorino  
County Executive

Department of Environmental Facilities

Thomas J. Lauro, P.E.  
Commissioner

April 15, 2011

Mr. Jon P. Dalgren, Senior Geologist  
Tim Miller Associates, Inc.  
10 North Street  
Cold Spring, NY 10516

Re: Buena Vista Teutonia Development  
Buena Vista Avenue  
Yonkers, NY

Dear Mr. Pearson:

We have received your e-mail dated April 13, 2011 with attached correspondence for the proposed redevelopment in the downtown waterfront area of Yonkers located along Buena Vista Avenue with an estimated sewage flow of 29,900 GPD.

Please be advised that the County Trunk Sewer and the Yonkers Joint Wastewater Treatment Plant have sufficient capacity to accommodate the anticipated sewage flows to be generated by the above captioned project.

However, we propose as we have done in other County sewer districts that the additional flow to the system is offset by reductions in inflow/infiltration (I&I). The removal for this project should be on a three for one ratio similar to the requirements by NYSDEC for sewer extension approvals in the New Rochelle sewer district. We feel this project warrants the same consideration.

The following information is provided as per your request:

#### YONKERS JOINT TREATMENT PLANT


##### Flow Capacities

Actual Flow: 89MGD

Permitted Flow: 120MGD (12-month rolling average)

Please call should you have any questions or require additional information.

Very truly yours,

A handwritten signature in black ink, appearing to read "John K. Devany". The signature is fluid and cursive, with the first name "John" and last name "Devany" clearly legible.

John K. Devany  
Construction Coordinator

CC: Joseph Gibney, P.E., Director of Wastewater Treatment  
Michael J. Facelle, Director of Maintenance  
Marion Pompa, Associate Engineer